



Microbac Laboratories Inc., Pittsburgh Division
 CERTIFICATE OF ANALYSIS
 A312958

Freeport Area School District

Project Name: Water Testing

Eric Mailki
 PO BOX C
 Freeport, PA 16229

Project / PO Number: 2620
 Received: 09/18/2023
 Reported: 10/04/2023

Analytical Testing Parameters

Client Sample ID:	H.S. Trainer	Collected By:	Client
Sample Matrix:	Drinking Water	Collection Date:	09/18/2023 10:45
Lab Sample ID:	A312958-01		

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Microbiology	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: Legiolert								
Legionella pneumophila	<1.0		1.0	MPN/100mL	Y	09/20/23 0914	09/27/23 2050	SAD

Client Sample ID:	H.S. Library #6	Collected By:	Client
Sample Matrix:	Drinking Water	Collection Date:	09/18/2023 10:50
Lab Sample ID:	A312958-02		

Analyses Performed by: Microbac Laboratories, Inc. - Chicagoland

Microbiology	Result	Limit(s)	RL	Units	Note	Prepared	Analyzed	Analyst
Method: Legiolert								
Legionella pneumophila	<1.0		1.0	MPN/100mL	Y	09/20/23 0914	09/27/23 2050	SAD

Results in **bold** have exceeded a limit defined for this project. Limits are provided for reference but as regulatory limits change frequently, Microbac Laboratories, Inc. advises the recipient of this report to confirm such limits and units of concentration with the appropriate Federal, state or local authorities before acting on the data.

Definitions

- MPN/100mL Most Probable Number per 100 Milliliters
- RL: Reporting Limit
- Y: This analyte is not on the laboratory's current scope of accreditation.

Project Requested Certification(s)

Microbac Laboratories Inc., Pittsburgh Division
 02-00257

Pennsylvania Department of Environmental Protection
 Pennsylvania Department of Environmental Protection - PARULE

Microbac Laboratories, Inc. - Chicagoland
 12006
 68-04863

New York State Department of Health
 Pennsylvania Department of Environmental Protection



Microbac Laboratories Inc., Pittsburgh Division

CERTIFICATE OF ANALYSIS

A312958

Report Comments

Samples were received in proper condition and the reported results conform to applicable accreditation standard unless otherwise noted.

*The data and information on this, and other accompanying documents, represents only the sample(s) analyzed. This report is incomplete unless all pages indicated in the footnote are present and an authorized signature is included. **The services were provided under and subject to Microbac's standard terms and conditions which can be located and reviewed at <https://www.microbac.com/standard-terms-conditions>.***

Reviewed and Approved By:

A handwritten signature in blue ink that reads "Carolyn M. Vollentine".

Carolyn Vollentine

Service Center Manager

Reported: 10/04/2023 10:32



A 3 I 2 9 5 8
Freeport Area School District

PM: Carolyn Volentine

CHAIN OF CUSTODY RECORD

umber

Instructions on back

TO BE COMPLETED BY MICROBAC

Lab Report Address

Client Name: Freeport Area school District

Address: 625 South Pike Road

City, State, Zip: Sarver, PA 16055

Contact: Eric Mailli

Telephone No.: (724) 321-1529

Send Report via: Mail Fax e-mail (address)

Project: High School legionell - Sample

Sampled by (PRINT):

Invoice Address

Client Name: Freeport Area School District

Address: P.O. Drawer "C"

City, State, Zip: Freeport, PA 16229

Contact: Accounts payable, Donia Kersul ext. 14

Telephone No.: (724) 295-5141

Location: High School, 625 S. Pike rd. PO No.: 2620

Sampler Signature:

Routine (5 to 7 business days)
 RUSH* (notify lab)

Report Type

Results Only Level 1 Level 2 Level 3 Level 4 EDD

Send Invoice via: Mail Fax e-mail (address)

Compliance Monitoring? Yes No
 Agency/Program

Sampler Phone No.:

* Matrix Types: Soil/Solid (S), Sludge, Oil, Wipe, Drinking Water (DW), Groundwater (GW), Surface Water (SW), Waste Water (WW), Other (specify)
** Preservative Types: (1) HNO3, (2) H2SO4, (3) HCl, (4) NaOH, (5) Zinc Acetate, (6) Methanol, (7) Sodium Bisulfate, (8) Sodium Thiosulfate, (9) Hexane, (U) Unpreserved

REQUESTED ANALYSIS

Lab ID	Client Sample ID	Date Collected	Time Collected	No. of Containers	Matrix	Grab / Comp	Preservative Types **	Legionella	Additional Notes
01	H.S. Trainer	09/18/23	10:45	1	DW	G	8	x	
02	H.S. Library #6	09/18/23	10:50	1	DW	G	8	X	

Possible Hazard Identification Comments

Hazardous Non-Hazardous Radioactive

Sample Disposition Dispose as appropriate Return Archive

Relinquished By (signature)

Eric Mailli

Relinquished By (signature)

Mailli

Relinquished By (signature)

Date/Time

9-18-23 1320

Date/Time

9/18/23 1435

Date/Time

Received By (signature)

Mailli

Received By (signature)

Mailli

Received By (signature)

Date/Time

9/18/23 1320

Date/Time

9/18/23 1445

Date/Time